



CDSS

WILL LIGHTBOURNE
DIRECTOR

STATE OF CALIFORNIA—HEALTH AND HUMAN SERVICES AGENCY
DEPARTMENT OF SOCIAL SERVICES
744 P Street • Sacramento, CA 95814 • www.cdss.ca.gov



EDMUND G. BROWN JR.
GOVERNOR

November 14, 2017

PIN 17-11-CCL

TO: ALL COMMUNITY CARE PROVIDERS

Original signed by Pamela Dickfoss

PAMELA DICKFOSS

FROM: Deputy Director
Community Care Licensing Division

SUBJECT: **U.S. CONSUMER PRODUCT SAFETY COMMISSION FIRE
EXTINGUISHER RECALL**

Provider Information Notice (PIN) Summary

PIN 17-11-CCL. The purpose of this PIN is to inform Community Care Providers of the recent recall of Kidde plastic handled and push-button Pindicator fire extinguishers due to failure to discharge and nozzle detachment.

On November 2, 2017, the U.S. Consumer Product Safety Commission issued a safety recall on Kidde fire extinguishers with plastic handles and push button pindicators due to failure to discharge and nozzle detachment.

The specific fire extinguishers recalled and additional information regarding the recall can be found on the Consumer Product Safety Commission's website by visiting:
<https://www.cpsc.gov/Recalls/2018/Kidde-Recalls-Fire-Extinguishers-with-Plastic%20Handles-Due-to-Failure-to-Discharge-and-Nozzle-Detachment-One-Death-Reported>

Licensees should immediately contact Kidde to request a free replacement fire extinguisher and for instructions on returning the recalled unit, as it may not work properly in a fire emergency.

If you have any questions, please contact your local regional office.